

58  
223

## Initial Notification of Applicability<sup>1</sup>

National Emission Standards for Hazardous Air Pollutants:  
Stationary Reciprocating Internal Combustion Engines  
40 CFR Part 63 Subpart ZZZZ

REC'D  
AUG 30 2010  
APCO

☐ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112

Compliance Date: ☐ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

**Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:**

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of Sharon Springs

Facility name (if different): City of Sharon Springs Power Plant

Facility (physical location) address: 306 South Main

My facility is a (please choose one): ☐ Major source ☐ Area source  
☐ Synthetic minor

<sup>a</sup> This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

<sup>1</sup> Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner name/title: City of Sharon Springs

---

Owner/company address: 111 West 2<sup>nd</sup>, PO Box 490  
Sharon Springs, Kansas 67758

---

Owner telephone number: 785-852-4257

---

Owner email address (if available): [sscity@fairpoint.net](mailto:sscity@fairpoint.net)  
[sspowerplant@fairpoint.net](mailto:sspowerplant@fairpoint.net)

If the Operator information is different from the Owner, please provide the following:

Operator name/title: Brad Hatfield; General employee

---

Operator telephone number: 785-852-4232

---

Operator email address (if available): [sspowerplant@fairpoint.net](mailto:sspowerplant@fairpoint.net)

---

I hereby certify that the information presented herein is correct to the best of my knowledge.

Deborah M. Benusch  
(Signature)

8-26-10  
(Date)

City Clerk  
(Name/title)

(785) 852-4257  
(Telephone No.)

## City of Sharon Springs - / City of Sharon Springs Power Plant

Power Plant Engines Covered – 8-26-10

The engines at the plant are used for Emergency Standby for the Municipal Power Plant – All of the engines are CI (have Combustion Ignition)

We have four (4) Engines

# 1 Fairbanks Morse – H.P. 1470 – RPM 720

#2 Fairbanks Morse – H.P. 1440 – RPM 720

#3 Superior - H.P. 575 – RPM 720

#4 Fairbanks Morse – H.P. 750 – RPM 720

All Engines are Dual Fuel Diesel / Natural Gas

We are a municipal plant so we are considered an area source.

Our SIC # 4911 – Municipal Power Plants

NAICS # 221112